



January 19, 2024

Michael Ferraro
OHM BOCES Utica City School District
320 Elizabeth St.
Utica, NY 13501

RE: Project: COLUMBUS ELEMENTARY 1/11
Pace Project No.: 70284326

Dear Michael Ferraro:

Enclosed are the analytical results for sample(s) received by the laboratory on January 16, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Jack M. Germano
jack.germano@pacelabs.com
516-370-6012
Project Manager

Enclosures

cc: Erica Molina, OHM BOCES Utica City School District
OHM BOCES Safety Services, OHM BOCES Utica City
School District
Tiffany Service, OHM BOCES Utica City School District



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

Sample: COLUMBUS 1A	Lab ID: 70284326001	Collected: 01/11/24 07:17	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 10:38	7439-92-1	

Sample: COLUMBUS 16	Lab ID: 70284326002	Collected: 01/11/24 07:18	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 10:43	7439-92-1	

Sample: COLUMBUS 13	Lab ID: 70284326003	Collected: 01/11/24 07:20	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	14.2	ug/L	1.0	1		01/18/24 10:44	7439-92-1	

Sample: COLUMBUS 14	Lab ID: 70284326004	Collected: 01/11/24 07:22	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	32.1	ug/L	1.0	1		01/18/24 10:46	7439-92-1	

Sample: COLUMBUS 15	Lab ID: 70284326005	Collected: 01/11/24 07:24	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	12.4	ug/L	1.0	1		01/18/24 10:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

Sample: COLUMBUS 16	Lab ID: 70284326006	Collected: 01/11/24 07:21	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	10.0	ug/L	1.0	1		01/18/24 10:49	7439-92-1	

Sample: COLUMBUS 17	Lab ID: 70284326007	Collected: 01/11/24 07:23	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.8	ug/L	1.0	1		01/18/24 10:11	7439-92-1	

Sample: COLUMBUS 18	Lab ID: 70284326008	Collected: 01/11/24 07:27	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 10:12	7439-92-1	

Sample: COLUMBUS 19	Lab ID: 70284326009	Collected: 01/11/24 07:25	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	13.8	ug/L	1.0	1		01/18/24 10:53	7439-92-1	

Sample: COLUMBUS 22	Lab ID: 70284326010	Collected: 01/11/24 07:30	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 10:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

Sample: COLUMBUS 24	Lab ID: 70284326011	Collected: 01/11/24 07:34	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 10:57	7439-92-1	

Sample: COLUMBUS 25	Lab ID: 70284326012	Collected: 01/11/24 07:39	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 10:58	7439-92-1	

Sample: COLUMBUS 27	Lab ID: 70284326013	Collected: 01/11/24 07:36	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		01/18/24 11:00	7439-92-1	

Sample: COLUMBUS 28	Lab ID: 70284326014	Collected: 01/11/24 07:37	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		01/18/24 11:01	7439-92-1	

Sample: COLUMBUS 29	Lab ID: 70284326015	Collected: 01/11/24 07:38	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		01/18/24 11:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

Sample: COLUMBUS 39		Lab ID: 70284326016	Collected: 01/11/24 06:58	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/18/24 11:04	7439-92-1	

Sample: COLUMBUS 41		Lab ID: 70284326017	Collected: 01/11/24 06:49	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	11.3	ug/L	1.0	1		01/18/24 11:06	7439-92-1	

Sample: COLUMBUS 44		Lab ID: 70284326018	Collected: 01/11/24 06:54	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/18/24 11:07	7439-92-1	

Sample: COLUMBUS 45		Lab ID: 70284326019	Collected: 01/11/24 06:50	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.2	ug/L	1.0	1		01/18/24 11:12	7439-92-1	

Sample: COLUMBUS 46		Lab ID: 70284326020	Collected: 01/11/24 06:55	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.4	ug/L	1.0	1		01/18/24 11:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

Sample: COLUMBUS 47	Lab ID: 70284326021	Collected: 01/11/24 06:51	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.7	ug/L	1.0	1		01/18/24 11:15	7439-92-1	

Sample: COLUMBUS 48	Lab ID: 70284326022	Collected: 01/11/24 06:57	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	34.9	ug/L	1.0	1		01/18/24 11:20	7439-92-1	

Sample: COLUMBUS 62	Lab ID: 70284326023	Collected: 01/11/24 07:04	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.7	ug/L	1.0	1		01/18/24 11:32	7439-92-1	

Sample: COLUMBUS 66	Lab ID: 70284326024	Collected: 01/11/24 07:05	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	20.8	ug/L	1.0	1		01/18/24 11:35	7439-92-1	

Sample: COLUMBUS 70	Lab ID: 70284326025	Collected: 01/11/24 07:07	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 11:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

Sample: COLUMBUS 71	Lab ID: 70284326026	Collected: 01/11/24 07:06	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		01/18/24 11:41	7439-92-1	

Sample: COLUMBUS 72	Lab ID: 70284326027	Collected: 01/11/24 07:09	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 11:44	7439-92-1	

Sample: COLUMBUS 74	Lab ID: 70284326028	Collected: 01/11/24 07:10	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 11:50	7439-92-1	

Sample: COLUMBUS 75	Lab ID: 70284326029	Collected: 01/11/24 07:11	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		01/18/24 11:53	7439-92-1	

Sample: COLUMBUS 77	Lab ID: 70284326030	Collected: 01/11/24 07:14	Received: 01/16/24 08:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 11:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

Sample: COLUMBUS 78		Lab ID: 70284326031	Collected: 01/11/24 07:15	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.0	ug/L	1.0	1		01/18/24 15:14	7439-92-1	

Sample: COLUMBUS 79		Lab ID: 70284326032	Collected: 01/11/24 07:31	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	25.7	ug/L	1.0	1		01/18/24 15:19	7439-92-1	

Sample: COLUMBUS 80		Lab ID: 70284326033	Collected: 01/11/24 07:32	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	13.1	ug/L	1.0	1		01/18/24 15:23	7439-92-1	

Sample: COLUMBUS 86 RM 118 CAFE KIT.SI		Lab ID: 70284326034	Collected: 01/11/24 06:45	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 15:31	7439-92-1	

Sample: COLUMBUS 87 RM 118 CAFE KIT.SI		Lab ID: 70284326035	Collected: 01/11/24 06:46	Received: 01/16/24 08:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/18/24 15:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

Sample: COLUMBUS 88 RM 118 CAFE KIT.SI **Lab ID:** 70284326036 Collected: 01/11/24 06:47 Received: 01/16/24 08:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

200.8 MET ICPMS Drinking Water
Analytical Method: EPA 200.8
Pace Analytical Services - Melville

Lead	<1.0	ug/L	1.0	1		01/18/24 15:34	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Sample: COLUMBUS 89 RM 113 **Lab ID:** 70284326037 Collected: 01/11/24 07:01 Received: 01/16/24 08:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

200.8 MET ICPMS Drinking Water
Analytical Method: EPA 200.8
Pace Analytical Services - Melville

Lead	7.4	ug/L	1.0	1		01/18/24 15:36	7439-92-1	
------	-----	------	-----	---	--	----------------	-----------	--

Sample: COLUMBUS 90 DF ACROSS 122 **Lab ID:** 70284326038 Collected: 01/11/24 07:42 Received: 01/16/24 08:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

200.8 MET ICPMS Drinking Water
Analytical Method: EPA 200.8
Pace Analytical Services - Melville

Lead	<1.0	ug/L	1.0	1		01/18/24 15:37	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

QC Batch: 334387

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70284326007, 70284326008

METHOD BLANK: 1718316

Matrix: Water

Associated Lab Samples: 70284326007, 70284326008

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/18/24 09:40	

LABORATORY CONTROL SAMPLE: 1718317

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.3	101	85-115	

MATRIX SPIKE SAMPLE: 1718319

Parameter	Units	70284496001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	52.1	104	70-130	

MATRIX SPIKE SAMPLE: 1718322

Parameter	Units	70284496002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	52.0	104	70-130	

SAMPLE DUPLICATE: 1718318

Parameter	Units	70284496001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1718321

Parameter	Units	70284496002 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

QC Batch:	334389	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70284326001, 70284326002, 70284326003, 70284326004, 70284326005, 70284326006, 70284326009, 70284326010, 70284326011, 70284326012, 70284326013, 70284326014, 70284326015, 70284326016, 70284326017, 70284326018, 70284326019, 70284326020, 70284326021		

METHOD BLANK:	1718327	Matrix:	Water
Associated Lab Samples:	70284326001, 70284326002, 70284326003, 70284326004, 70284326005, 70284326006, 70284326009, 70284326010, 70284326011, 70284326012, 70284326013, 70284326014, 70284326015, 70284326016, 70284326017, 70284326018, 70284326019, 70284326020, 70284326021		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/18/24 10:28	

LABORATORY CONTROL SAMPLE:	1718328					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.6	103	85-115	

MATRIX SPIKE SAMPLE:	1718330						
Parameter	Units	70284454002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	52.3	104	70-130	

MATRIX SPIKE SAMPLE:	1718332						
Parameter	Units	70284326001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	50.5	101	70-130	

SAMPLE DUPLICATE:	1718329				
Parameter	Units	70284454002 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	1718331				
Parameter	Units	70284326001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

QC Batch:	334390	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70284326022, 70284326023, 70284326024, 70284326025, 70284326026, 70284326027, 70284326028, 70284326029, 70284326030		

METHOD BLANK:	1718333	Matrix:	Water
Associated Lab Samples:	70284326022, 70284326023, 70284326024, 70284326025, 70284326026, 70284326027, 70284326028, 70284326029, 70284326030		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/18/24 11:17	

LABORATORY CONTROL SAMPLE: 1718334						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.9	102	85-115	

MATRIX SPIKE SAMPLE: 1718336							
Parameter	Units	70284326022 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	34.9	50	78.7	88	70-130	

MATRIX SPIKE SAMPLE: 1718338							
Parameter	Units	70284327001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	53.2	106	70-130	

SAMPLE DUPLICATE: 1718335					
Parameter	Units	70284326022 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	34.9	35.1	1	

SAMPLE DUPLICATE: 1718337					
Parameter	Units	70284327001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

QC Batch: 334394

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70284326031

METHOD BLANK: 1718357

Matrix: Water

Associated Lab Samples: 70284326031

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/18/24 14:27	

LABORATORY CONTROL SAMPLE: 1718358

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.8	104	85-115	

MATRIX SPIKE SAMPLE: 1718360

Parameter	Units	70284330010 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.1	50	52.8	103	70-130	

MATRIX SPIKE SAMPLE: 1718362

Parameter	Units	70284330011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.2	50	55.0	100	70-130	

SAMPLE DUPLICATE: 1718359

Parameter	Units	70284330010 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.1	1.1	2	

SAMPLE DUPLICATE: 1718361

Parameter	Units	70284330011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	5.2	5.2	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

QC Batch:	334395	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70284326032, 70284326033, 70284326034, 70284326035, 70284326036, 70284326037, 70284326038		

METHOD BLANK:	1718363	Matrix:	Water
Associated Lab Samples:	70284326032, 70284326033, 70284326034, 70284326035, 70284326036, 70284326037, 70284326038		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/18/24 15:16	

LABORATORY CONTROL SAMPLE: 1718364						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.3	103	85-115	

MATRIX SPIKE SAMPLE: 1718366							
Parameter	Units	70284326032 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	25.7	50	73.4	95	70-130	

MATRIX SPIKE SAMPLE: 1718368							
Parameter	Units	70284326033 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	13.1	50	62.7	99	70-130	

SAMPLE DUPLICATE: 1718365					
Parameter	Units	70284326032 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	25.7	26.6	4	

SAMPLE DUPLICATE: 1718367					
Parameter	Units	70284326033 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	13.1	12.7	3	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: COLUMBUS ELEMENTARY 1/11

Pace Project No.: 70284326

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70284326001	COLUMBUS 1A	EPA 200.8	334389		
70284326002	COLUMBUS 16	EPA 200.8	334389		
70284326003	COLUMBUS 13	EPA 200.8	334389		
70284326004	COLUMBUS 14	EPA 200.8	334389		
70284326005	COLUMBUS 15	EPA 200.8	334389		
70284326006	COLUMBUS 16	EPA 200.8	334389		
70284326007	COLUMBUS 17	EPA 200.8	334387		
70284326008	COLUMBUS 18	EPA 200.8	334387		
70284326009	COLUMBUS 19	EPA 200.8	334389		
70284326010	COLUMBUS 22	EPA 200.8	334389		
70284326011	COLUMBUS 24	EPA 200.8	334389		
70284326012	COLUMBUS 25	EPA 200.8	334389		
70284326013	COLUMBUS 27	EPA 200.8	334389		
70284326014	COLUMBUS 28	EPA 200.8	334389		
70284326015	COLUMBUS 29	EPA 200.8	334389		
70284326016	COLUMBUS 39	EPA 200.8	334389		
70284326017	COLUMBUS 41	EPA 200.8	334389		
70284326018	COLUMBUS 44	EPA 200.8	334389		
70284326019	COLUMBUS 45	EPA 200.8	334389		
70284326020	COLUMBUS 46	EPA 200.8	334389		
70284326021	COLUMBUS 47	EPA 200.8	334389		
70284326022	COLUMBUS 48	EPA 200.8	334390		
70284326023	COLUMBUS 62	EPA 200.8	334390		
70284326024	COLUMBUS 66	EPA 200.8	334390		
70284326025	COLUMBUS 70	EPA 200.8	334390		
70284326026	COLUMBUS 71	EPA 200.8	334390		
70284326027	COLUMBUS 72	EPA 200.8	334390		
70284326028	COLUMBUS 74	EPA 200.8	334390		
70284326029	COLUMBUS 75	EPA 200.8	334390		
70284326030	COLUMBUS 77	EPA 200.8	334390		
70284326031	COLUMBUS 78	EPA 200.8	334394		
70284326032	COLUMBUS 79	EPA 200.8	334395		
70284326033	COLUMBUS 80	EPA 200.8	334395		
70284326034	COLUMBUS 86 RM 118 CAFE KIT.SI	EPA 200.8	334395		
70284326035	COLUMBUS 87 RM 118 CAFE KIT.SI	EPA 200.8	334395		
70284326036	COLUMBUS 88 RM 118 CAFE KIT.SI	EPA 200.8	334395		
70284326037	COLUMBUS 89 RM 113	EPA 200.8	334395		
70284326038	COLUMBUS 90 DF ACROSS 122	EPA 200.8	334395		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



Pace® Location Requested (City/State):
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Company Name:
Street Address:
Customer Project #:
Project Name:

Columbus Elementary

Ulica Central School District
929 York St, Ulica, NY 13502

Contact/Report To:
Tiffany Service
315-927-4110
taseservice@uticaschools.org

Invoice To:
Tiffany Service
taseservice@uticaschools.org

Purchase Order # (if applicable):
Quote #:

County / State origin of sample(s):
New York

Regulatory Program (DW, RCRA, etc.) as applicable. NY Lead in School DW

Rush (Pre-approval required):
Date Requested: [] Day [] 3 day [] 5 day [] Other:
Standard 30 business day

DW PWSID # or WW Permit # as applicable:

Field Filtered (if applicable): [] Yes [] No

Analyst:

* Matrix Codes (insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Cook

Customer Sample ID	Matrix *	Comp / Grab	Collected		Composite End	Res. CLZ	Number & Type of Containers	
			Date	Time			Plastic	Glass
<i>Columbus</i>	DW	G	7/11/2024	0777			1	
1a								
1b				0718				
13				0720				
14				0722				
15				0724				
16				0721				
17				0723				
18				0725 0727				
19				0725				
22				0730				

Customer Remarks / Special Conditions / Possible Hazards:
Lead

Collected By:
Printed Name: Chris Pulzer
Signature: *Chris Pulzer*
Requisitioned by/Company: (Signature)
Received by/Company: (Signature)
Date/Time: 1-15-24 11:00
Date/Time: 1/16 8:00
Date/Time: 1/16 4:10
Date/Time: 1/16 8:00

Additional Instructions from Pace®:
Coolers: 2-bx TH211
Thermometer ID: 15521135
Correction Factor (°C): +0.1
Obs. Temp. (°C): 8.4
Corrected Temp. (°C): 9.1
Tracking Number:
Delivered by: [] In-Person [] Courier
[] FedEx [] UPS [] Other
Page: 1 of 7

LAB USE ONLY - AMIX Workorder/Login Label Here
WO#: 70284326



** Container Size (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL Vial, (7) Encore, (8) TerraCore, (9) Other
*** Preservative Types: (1) None, (2) HClO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Specify Container Size **
Identify Container Preservative Type***
Analysis Requested
Proj. Mgr:
AcctNum / Client ID:
Table #:
Profile / Template:
Prelog / Bottle Ord. ID:
Sample Comment

Lab Use Only
Preservation non-conformance identified for sample

Company Name: Ulrica Central School District
Street Address: 929 York St, Ulrica, NY 13302

Contact/Report To: Tiffany Service
Phone #: 315-927-4110
E-Mail: tservice@ulricaschools.org
Cc E-Mail:

Invoice To: Tiffany Service
Invoice E-Mail: tservice@ulricaschools.org

Purchase Order # (if applicable):
Quote #:

County / State origin of sample: New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):
 1-2 Day 3-5 day 5-10 day Other

Date Results Requested: Standard 30 business day

Site Collection Info/Facility ID (as applicable):

Time Zone Collected: [] AK [] MT [] CT [] ET

Data Deliverables:
 Level II Level III Level IV
 EQUIS Other

*** Merit Codes (insert in Merit box below):** Drinking Water (DW), Ground Water (GW), Surface Water (SW), Sediment (SEP), Sludge (SL), Caulk (V), Other (OT)

Customer Sample ID	Merit *	Comp / Grab	Collected (for Composite Start)		Composite End	Res. CL2	Number & Type of Containers	200's Drinking Water (Pb only)	Sample Comment
			Date	Time					
Columbus 78	DW	G	1-11-2024	0715			1	X	
79				0731					
80				0732					
86 Per 118 Cage Left Sink 1				6645					
87 Per 118 Cage Right Sink 2				0646					
88 Per 118 Cage Hand Sink				0647					
89 Rm 113				0701					
90 DF across from 122				0742					

Site Collection Info/Facility ID (as applicable):

Specify Container Size **

Identify Container Preservative Type ***

Analysis Requested

Proj. Mgr:
 Lori Bayer
AccNum / Client ID:

Table #:
Profile / Template:
Prelog / Bottle Ord. ID:

Lab Use Only

Preservation non-conformance identified for

**** Container Size:** (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) Encore, (8) TerraCore, (9) Other

***** Preservative Type:** (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Additional Instructions from Pace*:

Coolers: 2-bx
Thermometer ID: 4711
Correction Factor (°C): -0.7
Dia. Temp. (°C): 8.7
Connected Temp. (°C): 9.1

Date/Time: 1/15/24 17:35
Tracking Number:

Date/Time: 1/16 4:10
Received by/Company (Signature): [Signature]

Date/Time: 1/16 8:00
Received by/Company (Signature): [Signature]

Delivered by: [] In-Person [] Courier
 FedEx UPS Other
Page: 4 of 4
ENV-FRM-CORQ-0019_V01_082123

Customer Remark / Special Conditions / Possible Hazards:

Collected By: Printed Name: Chris Putzer
Signature: [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace* Terms and Conditions found at <https://www.pacelabs.com/resource-library/resources/pace-terms-and-conditions/>

Customer Project #:

Project Name:

Relinquished by/Company (Signature):

Relinquished by/Company (Signature):

Relinquished by/Company (Signature):

Relinquished by/Company (Signature):

Relinquished by/Company (Signature):

Customer Remark / Special Conditions / Possible Hazards:

Collected By: Printed Name: Chris Putzer
Signature: [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace* Terms and Conditions found at <https://www.pacelabs.com/resource-library/resources/pace-terms-and-conditions/>

Customer Project #:

Project Name:

Relinquished by/Company (Signature):

Relinquished by/Company (Signature):

Relinquished by/Company (Signature):

Relinquished by/Company (Signature):

Relinquished by/Company (Signature):

Customer Remark / Special Conditions / Possible Hazards:

Collected By: Printed Name: Chris Putzer
Signature: [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Received by/Company (Signature): [Signature]

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace* Terms and Conditions found at <https://www.pacelabs.com/resource-library/resources/pace-terms-and-conditions/>

Customer Project #:

Project Name:

Relinquished by/Company (Signature):

Relinquished by/Company (Signature):

Relinquished by/Company (Signature):

Relinquished by/Company (Signature):

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace* Terms and Conditions found at <https://www.pacelabs.com/resource-library/resources/pace-terms-and-conditions/>

WO#: 70284326

Client Name: UCCSD

Project #

PM: JL1

Due Date: 01/24/24

Courier: Fed Ex UPS USPS Client Commercial Parcel Other

CLIENT: UCCSD

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No
 Packing Material: Bubble Wrap Bubble Bags Ziploc None Other Type of Ice: Wet Blue None

Thermometer Used: TH211 Correction Factor: +0.4 Samples on ice, cooling process has begun
 Cooler Temperature (°C): 8.2 Cooler Temperature Corrected (°C): 9.1 Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: ASF 1/16/24

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: SL <input checked="" type="checkbox"/> WF <input type="checkbox"/> OIL <input type="checkbox"/> OTHER	

Date and Initials of person checking preservation: ASF 1/16/24

All containers needing preservation have been <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A pH paper Lot # <u>Z13623</u> All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NaOH>12 Cyanide) Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl Sample #
	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A KI starch test strips Lot #	14. Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #	
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A Lead Acetate Strips Lot #	15. Positive for Sulfide? Y N
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

DATE AND INITIALS OF PERSON COMPLETING SECOND REVIEW: 1/16/24

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution: For sample 30s Columbus 79 & 80, only Columbus was written on bottles so label them based by time given

* PM (Project Manager) review is documented electronically in LIMS.

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - Affix Workorder/ Login Label Here



Scan QR Code for instructions

Pace
 Pace Analytical Long Island NY
 575 Broad Hollow Rd, Melville, NY 11747

Company Name: OHM BOCES Utica City School District
 Street Address: 320 Elizabeth St., Utica, NY 13501

Contact/Report To: Service, Tiffany
 Phone #: 315-793-8693
 E-Mail: taservice@uticaschools.org
 Cx E-Mail:

Invoice To:
 Invoice E-Mail:
 Purchase Order # (if applicable):
 Quote #:

Project Name: NY DW Lead Testing
 Master COC 1/9-1/12/2024
 8 schools in Utica CSD
 master chain of custody

Site Collection Info/Facility ID (as applicable):
 County / State origin of sample(s): New York

Time Zone Collected: [] AK [] PT [] MT [] CT [] ET
 Regulatory Program (DW, RCRA, etc.) as applicable:
 Rush (Pre-approval required):
 [] 2 Day [] 3 day [] 5 day [] Other: _____
 Date Results Requested: _____
 Field Filtered (if applicable): [] Yes [] No
 Analysis:

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End		Res. CL2	Number & Type of Containers			Sample Comment
			Date	Time	Date	Time		Plastic	Glass		
Jones Elementary	COC*		1-9-2024								
Hughes Elementary			1-9-2024								
Watson Williams Elementary			1-10-2024								
Martin Luther King Elementary			1-10-2024								
Albany Elementary			1-11-2024								
Columbus Elementary			1-11-2024								
Conkling Elementary			1-12-2024								
Herkner Elementary			1-12-2024								

Additional Instructions from Pace*:
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)
 Tracking Number:
 Date/Time:
 Date/Time:
 Date/Time:
 Date/Time:
 Delivered by: [] In-Person [] Courier
 [] FedEx [] UPS [] Other
 Page: COC of 8 5/yes

Customer Remarks / Special Conditions / Possible Hazards:
 *This is the master COC for 8 sites
 sampled 1-9-2024 to 1-12-2024 12 bottles
 Relinquished by/Company: Signature: Date/Time: 1-15-2024 14:36
 Relinquished by/Company: Signature: Date/Time: 1/15/24 1436
 Relinquished by/Company: Signature: Date/Time: 1/15/24 1436
 Relinquished by/Company: Signature: Date/Time: 1/16/24 1:30

Received by/Company: Signature: Date/Time: 1/16/24 4:10
 Received by/Company: Signature: Date/Time: 1/16/24 4:10
 Received by/Company: Signature: Date/Time: 1/16/24 4:10
 Received by/Company: Signature: Date/Time: 1/16/24 4:10

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace* Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/pace-term-and-conditions/>
 * Sign this as Chain of Custody by for all 8 sites/Lab attach this to all reports
 Pace 2 of 2
 Pace Analytical
 575 Broad Hollow Rd, Melville, NY 11747
 315-793-8693
 taservice@uticaschools.org